

## § 408.197

new source subject to the provisions of this subpart:

Pollutant or pollutant property	Pretreatment standard
BOD5 .....	No limitation.
TSS .....	Do.
pH .....	Do.
Oil and grease .....	Do.

[40 FR 55786, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

## § 408.197 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations shall be the same as those specified for conventional pollutants (which are defined in § 401.16) in § 408.192 of this subpart for the best practicable control technology currently available (BPT).

[51 FR 24997, July 9, 1986]

## Subpart T—Alaskan Bottom Fish Processing Subcategory

SOURCE: 40 FR 55787, Dec. 1, 1975, unless otherwise noted.

## § 408.200 Applicability; description of the Alaskan bottom fish processing subcategory.

The provisions of this subpart are applicable to discharges resulting from the processing of bottom fish such as halibut in Alaska.

## § 408.201 Specialized definitions.

For the purpose of this subpart:

(a) Except as provided below, the general definitions, abbreviations and methods of analysis set forth in part 401 of this chapter shall apply to this subpart.

(b) The term *seafood* shall mean the raw material, including freshwater and saltwater fish and shellfish, to be processed, in the form in which it is received at the processing plant.

## 40 CFR Ch. I (7–1–00 Edition)

## § 408.202 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available.

Except as provided in §§ 125.30 through 125.32, any existing point source subject to this subpart shall achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT):

(a) Any Alaskan bottom fish processing facility located in population or processing centers including but not limited to Anchorage, Cordova, Juneau, Ketchikan, Kodiak, and Petersburg shall meet the following limitations:

Effluent characteristic	Effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days shall not exceed—
Metric units (kg/kg of seafood)		
TSS .....	3.1	1.9
Oil and grease .....	4.3	0.56
pH .....	( <sup>1</sup> )	( <sup>1</sup> )
English units (lb/1,000 lb of seafood)		
TSS .....	3.1	1.9
Oil and grease .....	4.3	0.56
pH .....	( <sup>1</sup> )	( <sup>1</sup> )

<sup>1</sup> Within the range 6.0 to 9.0.

(b) Any Alaskan bottom-fish processing facility not covered under § 408.202(a) shall meet the following limitations: No pollutants may be discharged which exceed 1.27 cm (0.5 inch) in any dimension.

[40 FR 55787, Dec. 1, 1975, as amended at 60 FR 33945, June 29, 1995]

## § 408.203 [Reserved]

## § 408.204 Pretreatment standards for existing sources.

Any existing source subject to this subpart that introduces process wastewater pollutants into a publicly owned treatment works must comply with 40 CFR part 403. In addition, the following pretreatment standard establishes the quantity or quality of pollutants or